



Government Of West Bengal
Office Of The Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.: IND/WB/FES/20182019/19142

Date: 06-03-2024

From:

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services

To: Wheaton International School

Mouza- Halal, Khatian No- 703 (New), 281, 533, 101/2, 78, 373, 374 (Old), Plot No- 591, 592, 593 (R.S.), 1029, 1030, 1031 (L.R.), Kestopur, P.O.- Chowpukuria, P.S.- Bagdogra, Dist- Darjeeling

Sub: Issuance of Fire Safety Certificate for the G+2 Storied School building under group Educational in name of Wheaton International School having Mouza- Halal, Khatian No- 703 (New), 281, 533, 101/2, 78, 373, 374 (Old), Plot No- 591, 592, 593 (R.S.), 1029, 1030, 1031 (L.R.), Kestopur, P.O.- Chowpukuria, P.S.- Bagdogra, Dist- Darjeeling.

This is in reference to your application no. 0125189240500032 dated 04-03-2024 regarding the Issuance of Fire Safety Certificate for the G+2 Storied School building under group Educational in name of Wheaton International School having Mouza- Halal, Khatian No- 703 (New), 281, 533, 101/2, 78, 373, 374 (Old), Plot No- 591, 592, 593 (R.S.), 1029, 1030, 1031 (L.R.), Kestopur, P.O.- Chowpukuria, P.S.- Bagdogra, Dist- Darjeeling.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances, No Parking board will be allowing on the driveway.
2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will be strictly maintaining.
3. Arrangements shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building by a Licensee agency and to keep those in perfectly good working condition all the times and it should be written in the register.
4. Adequate number of "NO SMOKING" boards should be displaying surrounding the premises.
5. Existing electrical wiring and installation of whole building should be carefully checking and maintenance regularly by a licensed electrician for any wear and tear at those, particularly wiring on false ceiling and ducts.
6. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and Testing.

7. Transformer and switchgear room should be protecting with automatic CO2 or D.C.P. Fire extinguisher conforming I.S specification.
 8. First Aid Firefighting system should be providing as per I.S specification.
 9. All the Firefighting Extinguisher should be test once in a year.
 10. If required the old Firefighting system should be replaced with new, the cables will be always laying in M.S conduit pipe continuously bonded to the earth.
 11. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
 12. A crew of trained Fireman under the experienced officer shall be depute and maintained round the clock for safety of the building.
 13. All employees should be trained to operate the Firefighting equipment of the factory, that they can operate the same in case of exigency.
 14. Mock fire drill and evacuation drill should be done periodically with participation of all officers' personnel and security guards.
 15. One standby Pump must be install within 3 months.
- A register for the recording of Mock fire drill, evacuation drill ,testing and checking of whole firefighting installation, electrical installation will be maintained & liable to produce the same to the authorized officer of this department on demand.
- This certificate is valid for 3 year u/r 18 of WBFS (Fire Prevention and Safety) Rules,2003 and renewable after 3 year from date of issue failing which this shall be revoked automatically.

Divisional Fire Officer, Darjeeling
Division, Darjeeling
West Bengal Fire & Emergency Services