



Government of West Bengal
Office of the Assistant Engineer
Siliguri RWS Sub Division
Public Health Engineering Directorate
E-mail: ae_aid_rws@wbphed.gov.in

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


Memo no. APHE/2024-25/28

Dated: 08-02-2026


To,
Wheaton International School
Kestopur, Chowpukuria P.S. Bagdogra


It is certified that an inspection team headed by C. Gosh, Assistant Engineer of Siliguri RWS Sub-Division inspected the Wheaton International School, Kestopur, Chowpukuria P.S. Bagdogra on 26-03-2024 and found that the Wheaton International School, Kestopur, Chowpukuria P.S. Bagdogra has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central/state Government.

This certificate is valid for 1 Year from the date of issued.


Assistant Engineer
Siliguri RWS Sub-Division
P.H.E.Dte.

Assistant Engineer
Siliguri RWS Sub-Division


Managing Trustee
Legacy Foundation Social Educational
Charitable Trust
Chowpukuria, Bagdogra, Darjeeling Dist
West Bengal-734014, India


Principal
Wheaton International School
Chowpukuria, Bagdogra, Darjeeling Dist
West Bengal - 734014, India



N. D. INTERNATIONAL

GOVERNMENT REGISTERED

An ISO 9001:2015 Company | Certificate : 23DQMS20



elaci
العلاج الطبيعي
CB-QMS-035

TEST REPORT

Certificate No : W(S)-(NN)/23-24/03686

Dated: 26.03.2026

SAMPLE SUBMITTED BY PARTY :

Page - 1 of 1

Name of Customer : Wheaton International School
Address : Siliguri
Description of Sample : Water
Mark on Sample : Nil
Sample Received on : 17.03.2026
Analysis Started on : 20.03.2026
Analysis Completed on : 23.03.2026

A. ORGANOLEPTIC & PHYSICAL PARAMETERS :

Sl.	Test Parameters	Test Method	Unit	Results	Norms as per IS 10500:2012	
					AL(Max.)	PL(Max.)
1	Colour	IS 3025 (Part 4)	Hazen	<1 (DL:1.0)	5	15
2	Appearance	—	—	Clear	—	—
3	Odour	IS 3025 (Part 5)	—	Agreeable	Agreeable	Agreeable
4	pH at 25°C	APHA 24th Edn, 4500 H ⁺ B	—	6.6	6.5 - 8.5	No Relaxation
5	Turbidity	APHA 24th Edn, 2130-B	NTU	2.05	1.0	5.0
6	Total Dissolved Solids	APHA 24th Edn, 2540-C	mg/L	86	500	2000

B. GENERAL PARAMETERS :

7	Calcium as Ca	APHA 24th Edn, 3500- Ca B	mg/L	12	75	200
8	Chloride as Cl	APHA 24th Edn, 4500 Cl-B	mg/L	2.9	250	1000
9	Iron as Fe	APHA 24th Edn, 3500- Fe B	mg/L	1.12	0.30	No Relaxation
10	Magnesium as Mg	APHA 24th Edn, 3500- Mg B	mg/L	3.4	30	100
11	Sulphate as SO ₄	APHA 24th Edn, 4500- SO ₄ ²⁻ E	mg/L	3.3	200	400
12	Total Alkalinity as CaCO ₃	APHA 24th Edn, 2320-B	mg/L	73.5	200	600
13	Total Hardness as CaCO ₃	APHA 24th Edn, 2340-C	mg/L	44	200	600

Note : 1. AL - Acceptable Limit. 2. PL - Permissible Limit, DL - Detection Limit.

Remarks : Chemically: Satisfactory for the above tested parameters.

Statement of Conformity is applied considering Decision Rule as per ISO Guide 98-4.

Note : Mark on Sample is provided by Customer & Laboratory is not Responsible and the sample is unsealed.

...END OF TEST REPORT...

Managing Trustee

Legacy Foundation Socy Educational

Charitable Trust

Dhemajote, P.O.-Chok

Bagdogra, Dist.-Darjeeling, WB 734014



For, N.D. International

K. P. De - CEO

(Authorised Signatory)

Principal

Wheaton International School

Chowdhura, Bagdogra, Darjeeling Dist.

1079, Block-F, New Alipore, Kolkata-700 053, Phone : 4021-6600-17 (18 Lines), 4021-6600-18

E-mail : ndinternational@gmail.com, Website : www.ndinternational.in